

Label plate for detector base IQ8Quad



Part-No.: 805576

Before or after the installation of the detector, the label plate can be inserted at the side slot of the IQ8Quad detector base.

Common technical data

-  For identification purposes the detector can be provided with the detector address and detector zone for ceilings with a maximum height of 3 m. A label can be attached to the inscription field. Blank labels can be marked when using a PC, e.g. SIGEL Part No. LP725-white (58 x 18 mm) or other suppliers of writing materials. There is a help file in the download area for creating the printing material. Applicable for base 1x Part No. 805590/91 with 805570; for 805593.10, 805594.10. Not to be used for base 1x Part No. 805590/91 in combination with 805571, 805572.50, 805573, 805574.