



CE Declaration of Conformity

HÜNDÜR KABLO ELEKTRİK SAN.ve TİC.LTD.ŞTİ

We declare that the products / products whose name, type and model and serial numbers are given below are produced in accordance with the specified standards or related documents in order to meet the requirements of Directive (s) 2006/95 / EC (73/23 / EEC).

REF STANDARDS INSTITUTION : 1783
REF CPR CERTIFICATE : 654696
REF TEST REPORTS : 647107 - 647115
STANDARDS : TS 13767
SCOPE OF DOCUMENT : FE180 TYPES CABLE
PRODUCT TYPE : JE-H(st)H FE180/E90

STRUCTURE
CONDUCTOR : Copper
INSULATION : Silicon
PET : Polyester Tape
PROTECTION : FiberGlass
DRAIN WIRE : SN/CU
FOIL : AL Foil
OUTER SHEET : HFFR


PLACES USED

: These cables can function in case of fire Halogen Free, flame retardant, low smoke density, Acidic (Corrosive) Gas Test, air ports, hospitals, industrials plants and especially where theres ectromagnetic interference.. Signal and communication cables are used as interference.. Signal and communication cables are used as an emergency circuits.

CONFIRMED BY

27.08.2023

Hündür Kablo Elektrik San.Ve Tic.Ltd.Şti.


HÜNDÜR KABLO ELEKTRİK SAN. TİC. LTD. ŞTİ
Vergi No & Dairesi : 4540390000 / Şişli
Piracı Is Merkezi A Blok Kat:5 No:27 Şişli - İstanbul
Tel : +90 212 249 0199 Fax : +90 212 249 8968

Hündür Kablo Elektrik San.ve Tic.Ltd.Şti.

Ömerli Mah.Kurtini Sok.No : 5 Hadımköy/Arnavutköy/İSTANBUL

Tel : 0212 886 93 41 Fax : 0212 886 93 42

Web : www.hunkakablo.com.tr e-mail : hunka@hunkakablo.com.tr