



Version 1

DESIGN & INSTALLATION GUIDE

This guide is aimed at supporting designers on Voice Alarm (VA) and Public Address (PA) systems and their use in conjunction with advanced fire detection systems. Incorporating the requirements of BS 5839 Part 8: 2013.

It highlights some of the main considerations in system design. This guide is intended as an aid and there is no substitute for reading the full standard.

Contents

Voice Alarm System Design

- Page 4.** Regulations for Voice Alarm
- Page 5.** Why do we need Voice Alarm
- Page 8.** Customer Requirements
- Page 11.** System Architecture

Loudspeaker Design

- Page 17.** Loudspeaker Layout
- Page 19.** Loudspeaker Types
- Page 24.** Loudspeaker Settings



Checklist for designing Voice Alarm Systems

VA SYSTEM DESIGN CHECKLIST

To achieve the right VA design, a number of simple steps need to be followed. This guide leads you through the steps in a sequence that will deliver a good design.

- ✓ **Regulations for Voice Alarm**
- ✓ **Why do we need Voice Alarm?**
- ✓ **Voice Alarm System Selection**
 - ✓ Management of Evacuation
 - ✓ Voice Alarm System Types
- ✓ **Customer Requirements**
 - ✓ Voice Alarm and Public Address
 - ✓ Microphones and other inputs
 - ✓ Background Music and Entertainment
 - ✓ Messages
- ✓ **System Architectures**
- ✓ **Loudspeaker Design**



Regulations for Voice Alarm

There is no substitute for a sound knowledge of the standards. BS 5839 Part 8: 2013 is the code of practice covering the requirements for the design, installation, commissioning and maintenance of Voice Alarm Systems.

It sets out in great detail the steps that should be followed to achieve a system meeting the needs of the application. This guide does not attempt to cover all of the detail of the standard but does set out to highlight the key considerations.

Other standards are also relevant and should be consulted:

BS 5839 Part 1

Design, Installation, Commissioning and Maintenance of fire detection and alarm systems.

BS EN 54 Part 16

Requirements for the design of Voice Alarm Control and Indicating equipment.

BS EN 54 Part 4

Requirements for the design of Power supply equipment

BS EN 54 Part 24

Requirements for the design and construction of Loudspeakers.

BS 7827

Code of practice for designing, specifying, maintaining and operating emergency sound systems at sports venues.

BS EN 50849

Sound systems for emergency purposes



Why do we need Voice Alarm?

VOICE ALARM IS THE FUTURE FOR FIRE ALARM SYSTEMS.

There is some well documented research^{1 2} into human behaviour in the event of fire. Most striking is the variation in the response to alarm signals:

- 13% of people react in a timely manner to bells
- 45% of people react to text information
- 75% of people react in a timely manner to voice messages

Further research shows that people's behaviour varies dependant on the environment, and in an emergency may exit the building using the same door they used to enter. The use of a clear voice message greatly increases response time and provides the opportunity to advise occupants of the safest emergency escape route.




What's that noise?



I'm out of here!



"Fire! Please leave the building immediately"



*Source of research data

1: Guylène Proulx, Ph.D, 'Misconceptions about human behaviour in fire emergencies' published in Canadian Consulting Engineer, March 1997, pp36, 38.


2: David Cantor, 'Studies of Human Behaviour in Fire: Empirical results and their implications for education and design.' Published by BRE, July 1985.

Checklist – Management of Evacuation

Before deciding on a VA System design, the evacuation requirements of the building must be established

- Is the building to be evacuated all at once (one out all out)?
- or does the building require a phased evacuation plan?
- In the example below, only part of the building is evacuated immediately
- Whilst other areas will have an alert or standby message

Note: For the Voice Alarm System in this example, only 3 circuits are needed to allow separate messages to be broadcast simultaneously.



LOUDSPEAKER CIRCUIT	LOCATION	VA ZONE
1	Front Office	1
2	Public Bar	2
2	Bar Store	2
3	Public Lounge	3
3	Staff Room	3



Voice Alarm System Types?

Once the evacuation strategy of the building is understood, the designer should assess the type of voice alarm system that should be used.

The level of manual control and the need for live messages versus automated messages will drive the decision on the type of system installed. BS 5839 Part 8 defines 5 types of systems and these are summarised below:

TYPES OF SYSTEMS

Type V1: Automatic evacuation

This system offers automatic operation of the voice alarm system against a pre-defined evacuation plan. The system may also have facilities for the manual operation of non-fire emergency messages, provided that these are automatically overridden by emergency messages.

Type V2: Live emergency messages

In addition to the automatic facilities provided by the Type V1 system, the Type V2 system provides the facility for automatic message initiation as well as the facility to broadcast live emergency messages by means of an all-call emergency microphone situated at a strategic control point. This allows supplementary live announcements to aid safe evacuation.

Type V3: Zonal live emergency messages

In addition to the functions of the Type V2, the facility to broadcast live emergency messages in pre-determined emergency zones, or groups of zones. This allows evacuation control in specific areas of the building where a pre-determined evacuation plan might not cover all eventualities.

Type V4: Manual controls

Type V4 system has the facility to select and direct stored emergency messages to individual zones as well as the ability to disable or enable emergency broadcast messages and display their status. This allows a well trained and disciplined staff to follow a pre-planned evacuation strategy when the automatic mode needs to be overridden.

Type V5: Engineered systems


Where the application falls outside the scope of type V1-V4, a type V5 system allows the design of a tailored solution based on the assessment of special or mutable risks.

Checklist – Customer Requirements

VOICE ALARM AND PUBLIC ADDRESS?

Is the system to be used only for Voice Alarm or a combination of Voice Alarm and Public Address, and maybe even music?

If so, the zoning requirements for Voice Alarm Evacuation may be different from Public Address.



- In the example shown opposite there is a requirement for 3 separate PA zones and 2 areas for music, as well as 3 VA zones. However, there are only 2 evacuation zones.

Note: For the Voice Alarm System example, only 3 circuits are needed to allow separate messages to be broadcast simultaneously. However once the PA and background music requirements are added, the minimum number of circuits required increases to 5.

LOUDSPEAKER CIRCUIT	LOCATION	VA ZONE	PA ZONE	MUSIC
1	Front Office	1	1	
2	Public Bar	2		1
3	Bar Store	2	2	
4	Public Lounge	3		2
5	Staff Room	3	3	

Checklist – For designing Voice Alarm Systems

CUSTOMER REQUIREMENTS

Microphones & Other Inputs

How many microphones are needed and what are they used for? Microphones may be used to broadcast live messages both in an emergency and for general public address.

For emergency use, microphones must be operated and be monitored in accordance with BS 5839 Part 8, and be certified to the requirements of EN 54-16.

Identify opportunities to broadcast miscellaneous announcements.

CUSTOMER REQUIREMENTS

Background Music and Entertainment

Does the system need music, if so how many sources and how is it to be routed?

Different areas of a building may need to be linked to entertainment systems. You need to identify the type and location of the music source eg. Multimedia player, Satellite TV, live streaming etc.



Examples include:

- Spot announcements
- General paging
- Landlord input in shopping centres
- Adverts
- Pre-recorded messages on a PC
- Audio visual presentations



Checklist – Messages

WHAT MESSAGES DO I NEED TO MEET THE NEEDS OF THE BUILDING?

Recommended messages are defined in the standards, and meet the needs of most buildings.

In some cases, messages may be tailored to suit special applications and may even involve coded alerts to warn staff, ahead of the public.



RECOMMENDED SEQUENCE OF MESSAGE AND TONE

ATTENTION-DRAWING SIGNAL	lasting 2s to 10s followed by
BRIEF SILENCE	lasting 1s to 2s followed by
EVACUATE MESSAGE	followed by
SILENCE	lasting 2s to 5s

EXAMPLE OF AN EVACUATE MESSAGE:

“Attention, please. Attention, please. Fire has been reported in the building. Please leave the building immediately, by the nearest exit. Do not use a lift.”

EXAMPLE OF AN ALERT MESSAGE:

“May I have your attention, please. May I have your attention, please. Fire has been reported in the building. Please listen for further instructions.”

Checklist – System Architectures

ARCHITECTURE – CENTRALISED OR DISTRIBUTED

The system architecture may be selected to suit the building. Some of today's solutions:

Three main variations of providing voice messages are available today, these are:

- Stand Alone Voice Enhanced sounders
- Central Rack Systems
- Distributed Rack Systems

All these types have possible use dependant on the type and size of the building where they are being installed.

Voice Enhanced sounders

Although these devices cannot be considered a true VA, they do offer voice messages, with each device containing a 'memory' chip that has a number of pre-recorded standard messages, that are operated directly from the fire alarm control panel. When planning the use of voice enhanced sounders it is important to remember the requirement to position them at 6m intervals in accordance with BS 5839-8: 2013.




It is important that the control panel has a 'synchronisation' capability so all the independent recorded messages are delivered at the same time.

Central Rack Systems

Central Rack Systems consist of a rack of amplifiers that control all the loudspeaker circuits that are radially wired as shown. This rack can also contain facilities for zone selection, music input, emergency and general paging announcements.

Considerations when using rack systems:

- The link between the fire control panel and the VA rack must be fully protected and monitored
- The correct cable sizes must be provided for the loudspeaker circuits, particularly if they extend across many floors
- The battery standby capacity must be properly calculated with some capacity to extend in the future




Distributed Rack Systems

Distributed Rack Systems allow the loudspeakers to be connected to local amplifier racks which are networked together around the building, or site, normally with fire rated fibre optic cable, as shown.

The benefits of this approach are:

- There is a lot less cable required for the loudspeaker circuits
- Shorter cable runs to localized racks
- The cables will often be smaller in size and therefore cost less
- The system can easily be extended as additional Distributed Racks can be added to the Voice Alarm network



Loudspeaker Design – What you need to know...

WHICH LOUDSPEAKER SHOULD I USE?

There are potentially several ways of providing intelligible coverage for any particular space. The selection of the type, quantity, location and orientation of loudspeakers is a critical part of voice alarm system design and is based on information about the use of the building such as:

- Acoustic environment
 - floor plans
 - building sections
 - material finishes
 - reverberation time
- Ambient noise level
- Climatic environment
- Area coverage requirement
- Mounting arrangements, for example ceiling tiles, wall, pole etc.
- Architectural design and relevance of the appearance of the loudspeaker
- Type of broadcast, i.e. if it is used for purposes other than voice alarm, such as commentary, background music etc.
- Inter-relationship between loudspeaker zones and fire compartments



Loudspeaker Layout/Placement



- The best loudspeaker layout should give an even spread of sound within a room.
- This may mean using more loudspeakers at lower sound pressure levels rather than one very loud one!

A single loudspeaker at a high setting will give a poor sound distribution.


A number of loudspeakers distributed evenly will give a better distribution and a better quality of sound.



Bad



Good distribution



Checklist – For Loudspeaker Design

BS 5839 Part 8: 2013 takes a more prescriptive approach than in previous editions providing simple loudspeaker spacing guidelines for designers.

In simple acoustic spaces, a competent person can estimate types, quantities and locations of loudspeakers required, using the above information.

There is a straight forward sequence to follow to arrive at a suitable loudspeaker design.



1 Decide loudspeaker layout /placement

2 Select loudspeaker types


3 Define setting for each loudspeaker

- 3.1 ✓ Assess background noise levels
- 3.2 ✓ Decide spacing and tappings
- 3.3 ✓ Calculate SPL required from loudspeaker
- 3.4 ✓ Calculate loudspeaker load

Checklist – For Loudspeaker Design


A distributed system will suit most common applications:

- Offices
- Shell and core building systems
- Classrooms
- Shop units




Plan view with ceiling loudspeakers

Loudspeakers spaced at regular intervals deliver an even distribution of sound. Listener ear level should be higher than 1.2m unless it's a child or very small person.



End view of ceiling loudspeakers

Wall loudspeakers may be used as an alternative distributed layout for high ceiling areas.





Alternative Loudspeaker Layout Options

Centralised Design and Hybrid or Combined Design

In certain circumstances a centralised design is better suited, for example in large open areas.

Combined

In other circumstances, a hybrid of centralised and distributed layouts may be required.



Loudspeaker Selection

CEILING LOUDSPEAKERS

This type of loudspeaker is ideal for open plan offices with false (suspended) ceilings.

Ceiling loudspeakers can give very good music reproduction and are often used in 'low level multipoint' systems where each loudspeaker is tapped at a low level to provide a smooth and even distribution of sound throughout the area of coverage.

Installations with a large number of ceiling loudspeakers (in an open-plan office, for example) will have them set in a grid pattern to maximize the coverage provided. Ceiling loudspeakers come in a range of diameters and are typically rated at a maximum of 6 watts.

CABINET LOUDSPEAKERS

A cabinet loudspeaker provides general coverage within a room of limited size.

Cabinet loudspeakers are suitable for paging announcements in small, quiet offices. Alternatively a number of suitable cabinet loudspeakers can be used in larger office areas to provide sufficient coverage.

Cabinet loudspeakers may also be used as ceiling loudspeakers where a suspended ceiling is not available.



Loudspeaker Selection

HORN LOUDSPEAKERS

Horn loudspeakers have two main attributes: they are weatherproof and are able to direct sound in a well defined pattern. Compact and sturdy 're-entrant' types (folded internally to make the unit shorter) are the most common types.

Due to their limited bandwidth, they should be used only for speech applications and amplifier high-pass filtering must be selected. If horn loudspeakers are fed with low frequencies, there is a risk of damage to the loudspeaker diaphragms.



PROJECTOR LOUDSPEAKERS

Projectors allow for more accurate positioning than cabinet loudspeakers but have better musicality than a horn.

The highly directional characteristic of projectors can be useful in saving amplifier power, in areas such as railway stations, a noisy machine shop, car parks and shopping centres.



Loudspeaker Selection

COLUMN LOUDSPEAKERS

Column loudspeakers consist of a number of driver units arranged in a vertical pattern and are usually confined to sound reinforcement applications rather than distributed P.A. systems.

They are designed to have a wide sound dispersion (radiation pattern) in a horizontal plane (from side to side) and narrow dispersion in the vertical plane.

This makes them effective in areas with difficult sound characteristics such as churches, auditoria, railway stations and airports.



SPHERICAL LOUDSPEAKERS

Ideal for open areas with high ceilings such as retail units. Sound is distributed around 360 degrees and the sphere is suspended at a convenient height above the floor.

With good sound reproduction quality, they are useful for voice and music in difficult applications.




Loudspeaker Design - Siting of Ceiling Speakers

LAYOUT/PLACEMENT


Where ceiling loudspeakers are to be mounted in a suspended ceiling, they are to be mounted on a square grid.

Ceiling loudspeakers shall be mounted at a maximum of 6m spacings to comply with the requirements of BS 5839-8: 2013.

**Ceiling
loudspeaker
mounted in
suspended
ceiling**



**Ceiling loudspeaker
mounted in suspended
ceiling**



**Loudspeaker
spacing**

Listener ear level should be higher than 1.2m unless it's a child or very small person.




Loudspeaker Options

CABINET LOUDSPEAKERS LAYOUT


Layout/Placement

Loudspeakers are to be wall mounted, and they should ideally be fitted at a height of 2.5m to 3m and spaced at a maximum of 6m apart along the wall.

Power settings should be set to give at least 10dB above the background noise level, at the furthest point from the loudspeaker.



As general guidance, in rooms less than 6m wide, cabinets can be fitted along one wall only. Above 6m the loudspeakers should be fitted to opposing walls.



Define Loudspeaker Settings

As well as layout, an intelligible Voice Alarm System is dependant on the sound level of the broadcast message.


Calculate Sound Pressure Level (SPL) required from each loudspeaker – Step 1:

Assess background noise level:

The Sound Pressure Level (SPL) required depends greatly on the background noise levels.

Typically the System design should aim to deliver SPL at around 10dB above ambient.

The table gives some typical sound levels in different environments.





Define Loudspeaker Settings

Calculate SPL required from Loudspeaker – Step 2:

Sound pressure level:

Sound pressure falls off rapidly with distance and there is a loss of 6dB every time the distance doubles away from the loudspeaker.

To achieve the desired sound pressure at a certain distance away from the loudspeaker, the loss must be calculated.



DISTANCE FROM SOURCE (M)	REDUCTION IN DB (A)
1	0
2	6
3	9.2
4	12
5	13.9
6	15.5
7	16.9
8	18
9	19
10	20

Example

Distance from loudspeaker = 4m

Ambient noise level = 61 dBA

Target SPL (61db+10db) = 71 dBA

DB loss over 4m = 12 dBA

Loudspeaker setting at 1m = At least 83 dBA at 1m

Define Loudspeaker Settings

CALCULATE SPL REQUIRED FROM EACH LOUDSPEAKER

Step 3:

Loudspeaker tapping:

Once the sound pressure level is known, the tap setting of the Loudspeaker can be defined. Loudspeaker data sheets give the power needed to achieve the SPL at 1m.

The table below can also be used to define typical tap settings for ceiling Loudspeakers at different ceiling heights.

Typical Tap Settings

CEILING HEIGHT	BACKGROUND NOISE LEVEL				
	65db (A)	70db (A)	75db (A)	80db (A)	85db (A)
2.5	0.75	0.75	0.75	1.5	3
3	0.75	0.75	0.75	3	6
3.5	0.75	0.75	1.5	6	-
4	0.75	0.75	3	6	-
4.5	0.75	0.75	3	-	-
5	0.75	1.5	6	-	-
5.5	0.75	1.5	6	-	-
6	0.75	3	6	-	-
6.5	0.75	3	-	-	-
7	1.5	3	-	-	-
7.5	1.5	3	-	-	-

Assumptions:

Listener height is 1.5 metres from FFL

Loudspeaker calculated is LSC-506 (91dB(A)@1w/1m)

Signal to noise headroom is 10dB minimum



Loudspeaker Design - Amplifier Loading

**What size amplifier do I need?
Calculate loudspeaker load for
each circuit:**


Once you have determined each individual Loudspeaker tapping, the total load for each Loudspeaker circuit can be calculated.

By adding the power requirement for every Loudspeaker, the total load for the Amplifier is calculated.

Add an additional 20% headroom to the speaker load calculation in order to determine the size of amplifier required.



Amplifier



$$12 \times 1.5W + 5 \times 3W + 1 \times 6W = 39W \text{ load}$$

$$+20\% = 8W$$

$$\text{Total Power} = 47W$$

Product Range

Honeywell has a PA/VA solution for all types of buildings and with our team of experts to support you every step of the way, it's never been easier to work with our products.

Two types of systems are available, including small 'Stand Alone' packages suitable for single storey buildings such as shops and offices, moving up to custom made 'Networked Systems' that will consist of a number of systems linked together for large structures such as exhibition halls and airports.

For more information

www.honeywellvoicealarm.com

Honeywell Security and Fire

Tel: +44 (0) 20 3409 1779

Email: HLSUKsalessupport@honeywell.com

140 Waterside Road

Hamilton Industrial Park

Leicester

LE5 1TN

Loudspeakers

Our full range of loudspeakers complies with BS5839 part 8 and EN 54 part 24 and includes:

- 5" and 6.5" Ceiling Loudspeakers
- 6W Cabinet Loudspeaker
- 10W and 20W Unidirectional Projection Loudspeakers
- 20W Bidirectional Projection Loudspeakers
- 20W and 40W Column Loudspeakers

Support

We offer a full Voice Alarm Support Service including:

- System design
- Acoustic design support and modelling (where required)
- Loudspeaker layouts
- Rack build
- Commissioning support
- Factory acceptance testing
- Training
- Technical Support