

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAi Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No.

0370-CPR-3812

In compliance with Regulation (EU) Nr.305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS:

- FIRE ALARM DEVICES. SOUNDERS

REFERENCE: **JBE-2145** – ADDRESSABLE SOUNDER WITH VISUAL INDICATOR

Placed on the market under the name of:

JADE BIRD FIRE ALARM INTERNATIONAL (EUROPE), S.L.

C/ DE TARRAGONA, 157 7º
08014 BARCELONA (SPAIN)

And produced in the manufacturing plant:

23/32308426

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 17th February 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed and modified on 2nd February 2024.

The monitoring assessment will be done before 28th February 2025

Bellaterra, 2nd February 2024




LGAi Technological Center, S.A.
Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility

0370-CPR-3812

Annex according to **EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006**

FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 3: FIRE ALARM DEVICES. SOUNDERS

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Sound level	4.2.	PASS
Frequency and sound pattern	4.3.	PASS
Durability	4.4.	PASS
Construction	4.5.	PASS
Marking and data	4.6.	PASS
Reproducibility	5.2.	PASS
Operational performance	5.3.	PASS
Durability	5.4.	PASS
Dry heat (operational)	5.5.	PASS
Dry heat (endurance)	5.6.	NA
Cold (operational)	5.7.	PASS
Damp heat, cyclic (operational)	5.8.	PASS
Damp heat, steady state (endurance)	5.9.	PASS
Damp heat, cyclic (endurance)	5.10.	NA
Sulfur dioxide (SO ₂) corrosion (endurance)	5.11.	PASS
Shock (operational)	5.12.	PASS
Impact (operational)	5.13.	PASS
Vibration, sinusoidal (operational)	5.14.	PASS
Vibration, sinusoidal (endurance)	5.15.	PASS
Electromagnetic compatibility (EMC), immunity (operational)	5.16.	PASS
Enclosure protection	5.17.	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Attention drawing signal and message broadcast sequences	C.3.1.	NA
Synchronisation (option with requirements)	C.3.2.	NA
General testing	C.4.	NA
Broadcast message performance	C.5.1.	NA
Attention drawing signal/silence/message sequence timing	C.5.2.	NA
Message synchronization testing (option with requirements)	C.5.3.	NA

ACCESSORIES	
JBE-2165	Detector Base with Four Terminals plus Screen Continuity Terminal