



Certificate of Continued Compliance 252350021/AA/00



Issued 30-01-2025
Expiry date 13-02-2026

Replaces 000239/05
Page 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Power Series Pro Model LE9080-EU Cellular Alarm Communicator
Trademark: DSC/Tyco
Type designation: LE9080-EU
Hardware / Software: UA716 Rev. 06 / N/A

Placed on the market under the name or trademark of:

Name of the manufacturer: Digital Security Controls, a division of Tyco Safety Products Canada Ltd.
Address: 3301 Langstaff Road
City: L4K 4L2 Concord
Country: CA

This certificate is granted to:

Name of the certificate holder: Digital Security Controls, a division of Tyco Safety Products Canada Ltd.
Address: 3301 Langstaff Road
City: L4K 4L2 Concord
Country: CA

Ron Scheepers
Managing director

Kiwa Nederland B.V.
Kiwa FSS Products
Wilmsdorf 50
Postbus 137
7300 AC Apeldoorn
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>

This certificate has THREE Annexes.



Remarks and observations

The following conditions are applicable:

Security grade: 3

Environmental class: II

Equipment class: Fixed

ATS class : SP4 (DP2 or DP3 when combined with LAN or PSTN)

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

Factory location:

Tyco International De Mexico S De R.L. De C.V.

Antonio Meucci Yg Gonzalez Camarena 10002

Parque Industrial La Ventana

87569, Matamoros

Mexico

Product inspection location:

AnB Rimex SA

Rue de l'Abbaye 89

4040, Herstal

Belgium

Documentation lodged for this Certificate of Continued Compliance**Test Reports:**

- Nemko Canada Inc.: HS3128_HSC3020C EN50130-4 Report 351820-2TRFEMC, 31 August 2018
- Nemko Canada Inc.: HS3128_HSC3020CP EN50130-4 Report 351713-2TRFEMC, 20 June 2018
- Nemko Canada Inc.: 3G9080-EU_HSC3020C EN50130-4 Report 351717-2TRFEMC, 22 June 2018
- Nemko Canada Inc.: 3G9080-EU_HSC3020CP EN50130-4 Report 351819-2TRFEMC, 28 June 2018
- Telefication: 180600139-001-Ver.3.00, 18 April 2019
- Telefication: 180600139-002-Ver.3.00, 12 March 2019
- Telefication: 180600139-ENV-Ver.1.00, 03 December 2018
- Telefication B.V.: P000118748-003-Ver 1.00, 29 September 2022
- Telefication B.V.: P000118748-ENV-Ver 1.00, 30 September 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10

June, 2014

Applied Standards

EN 50130-5

June, 2011

EN 50136-2

August, 2013

EN 50130-4+A1

October, 2014

EN 50136-1+A1

November, 2018

EN 50131-1+A1+A2+A3

June, 2020

The product as described in this certificate includes the following type designations

- | | |
|------------------------|--|
| - Product description: | Power Series Pro Model LE9080-EU Cellular Alarm Communicator |
| - Trademark: | DSC/Tyco |
| - Type designation: | LE9080-EU |
| - Hardware version: | UA716 Rev. 06 |
| - Software version: | N/A |