

Certificate

No. z2499a-11-E

Customer:

Schrack Technik GmbH
Seybelgasse 13
A-1235 Wien

Test sample(s):

- Keystone:
SCHRACK TOOLLESS LINE Module RJ45 shielded, Cat. 6A,
ISO/IEC 11801 AMD2
Part No.: HSEMRJ6GWA
- Datacable:
SCHRACK F/FTP Cable Cat.6A, 4x2xAWG23/1, 500 MHz, LSOH, blue
Part No.: HSEKP423HA, HSEKP823HA (duplex)
- Patchcord:
SCHRACK LED Patchcord RJ45 shielded, 500 MHz, Class E_A, 10GB, LSOH
Part No.: H6GSG02K0G, H6GSG03K0G, H6GSG06K0G

Applied standard(s):

- ISO/IEC 11801 AMD 1 (2008-04)

Class E_A

Results:

Up to a bandwidth of 500MHz the sample, a Channel (100m), meet the Class E_A limits of the specified standards and regulations.

4-Connector Channel (100m), Class E_A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, **no. P2499a-11-E**, from **January 19th, 2011** and shall only be applicable in conjunction with the test report.

Bexbach, January 19th, 2011



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de